

Declaration of Conformity

We,
Fuji Electric Co., Ltd. Head Office

**Gate City Ohsaki, East Tower, 11-2, Osaki 1-chome, Shinagawa-ku, Tokyo,
141-0032, Japan**

declare on our sole responsibility that the following
product conforms to all the relevant provisions.

Product Name: AC Power Regulator
Model Name: SINGLE-PHASE APR-V Series

Type: RPVE2□□□-□-□□□/UL
Rating: AC 100 – 240V 50/60 Hz
20A, 45A, 60A, 100A, 150A, 250A, 350A, 450A, 600A

Type: RPVE4□□□-□-□□□/UL
Rating: AC 380 – 480V 50/60 Hz
20A, 45A, 60A, 100A, 150A, 250A, 350A, 450A, 600A

Type: RPVE9□□□-□-□□□/UL
Rating: AC 250 – 305V 50/60 Hz
20A, 45A, 60A, 100A, 150A, 250A, 350A, 450A, 600A

Council Directives:
Low Voltage Directive (LVD) – 2014/35/EU
EMC Directive (EMC) – 2014/30/EU
RoHS Directive – 2011/65/EU + (EU) 2015/863

Applicable Standards:
EN62477-1:2012
+A11:2014+A1:2017 Safety requirements for power electronic converter systems and equipment

EN60947-4-3:2014 Low-voltage switchgear and controlgear – Part 4-3: Contactors and motor-starters – AC semiconductor controllers and contactors for nonmotor Loads

EN IEC63000:2018 Technical documentation for the assessment of electrical and electronic products with respect to the restriction of hazardous substances

Year to begin affixing CE Marking: 2021

Place: 2191, Karasugawa, Horigane,
Azumino-shi, Nagano, 399-8211, Japan

Signature:



Fuji Electric Meter Co., Ltd.

Full Name: Mitsuharu Komiyama
Title: Deputy General Manager

Issued: February 26, 2021
Revised: October 1, 2022

Technology & Production Control Div.